

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1517:122 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Commercial Products Group, 2519 4<sup>th</sup> Avenue, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731 FAX (309) 762-8215

**DESIGN:** Models LSEX-24CMC, LSEX-24CMR, LSEX-24CMB, LSEX-24CMA, LSEX-24WMC, LSEX-24WMR, LSEX-24WMB and LSEX-24WMA strobes. Models with suffix 24-C are for ceiling mount and Models with suffix 24-W are for wall mount. Units are intended for general signaling purposes. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as strobe lights for general signaling. Suitable for Class I, Group C and D; Class II, Group E, F and G hazardous locations. For indoor use only. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Not approved for public mode and not to be used as an evacuation signal for the hearing impaired.

**XLF:** 7300-0476:115

06-25-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 25, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager